



## **State Water Resources Control Board**

November 3, 2017

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7015 1520 0001 7928 4208

Ms. Otillia Alupoaie Site Manager Sacramento Housing and Redevelopment Agency 600 I Street #120 Sacramento, California 95814 oalupoaie@shra.org

SUBJECT:

NOTICE OF VIOLATION - NO FURTHER ACTION REQUIRED;

UNDERGROUND STORAGE TANK SYSTEM AT RIVERVIEW PLAZA,

600 "I" STREET, SACRAMENTO

Dear Ms. Alupoaie:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on October 24, 2017, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

| No. | Violation                                                                                                                                                            | Tank   | Start Date          | Stop Date           | Regulation           |
|-----|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|---------------------|---------------------|----------------------|
| 1   | Failure to Maintain Designated Operator (DO) Training Records Onsite – The annual DO facility employee training records were not available at the time of inspection | Diesel | October 24,<br>2017 | October 25,<br>2017 | 23 CCR<br>2715(f)(3) |

To our knowledge, the violation above has been corrected. Therefore, no further action is required at this time. The State Water Board reserves the right to bring an action against the owner and/or operator of the tank in violation, or it may recommend that Sacramento County Environmental Management Department (EMD) pursue enforcement, or Sacramento County EMD may elect to pursue enforcement independently.

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,

Amantha Henkel Senior Environmental Scientist UST Enforcement Unit

Office of Enforcement

cc: (via email only)

Ms. Jennea Monasterio
Environmental Specialist
Sacramento County Environmental
Management Department
monasterioj@saccounty.net

Mr. Jonathan Pollack Environmental Specialist Sacramento County Environmental Management Department pollacki@saccounty.net